



NOTES

1. SERVICE CONNECTION DETAILS ARE BASED ON GASKETED PVC PIPE AND FITTINGS. SEWER LATERAL PIPE SHALL BE PVC ASTM D3034.
2. SEWER CLEAN-OUTS NOT IN PAVEMENT SHALL HAVE CONCRETE COLLAR 18"x18"x4" AROUND THE COVER AND MUST BE INSTALLED AND ADJUSTED TO FINISHED GRADE AT THE RIGHT-OF-WAY/PROPERTY LINE.
3. CONNECTION TO EXISTING SANITARY SEWER PIPE SHALL BE MADE AS FOLLOWS:
 - *6" SS MAIN – PVC WYE AND FERNCO COUPLERS WITH SHEAR RINGS OR APPROVED EQUIVALENT
 - *8" AND LARGER SS MAIN – INSERT-A-TEE OR APPROVED EQUIVALENT
4. ALL PVC TO CLAY SERVICE CONNECTIONS UNDER LOAD BEARING SURFACES SHALL USE FERNCO TYPE CONNECTORS WITH STAINLESS STEEL SHEAR RINGS OR APPROVED EQUAL.
5. 90° FITTINGS ARE PROHIBITED. MINIMUM 6" PIPE LENGTH BETWEEN 45° FITTINGS.



City of Astoria
Public Works Department
 1095 Duane Street

Typical Sewer Connection Detail

Date Adopt. 11/01/12 **Date Rev.** 01/09/17

Dwg. Name: S-8 Typical Sewer Connection.dwg

DWG. NO.

S-8